

**Boneh Engineering Associates  
770 Lefferts Ave. #C1L  
Brooklyn, NY 11203  
Phone 718-493-6046  
jottenstein1@optonline.net**

June 4, 2007

Mr. Martin Kolt  
Active Ventilation Products  
P.O. Box 1521  
Newburgh, NY 12251-1521

Attn: Mr. Martin Kolt,

Re: Ventilation area of EC-25 ceiling vent with a plastic grille

Dear Mr. Kolt;

I have measured the net vent area of the ceiling vent with a plastic grille for the EC-25 that you sent me.

The overall dimensions of the plastic grille are approximately 9.5 inches x 5.75 inches. The net vent area of the plastic grille is 34 square inches after subtracting the thickness of the plastic bars.

I hope this information will be of use to you. If you have any information, please feel free to call me.

Very Truly Yours,

  
Jonathan Ottenstein P.E.

